



77 WEST ELMWOOD DRIVE ♦ SUITE 211 ♦ DAYTON, OHIO 45459 ♦ 937.610.3440

Clarification #1

**Modernization at Westdale Terrace OH5-7A, AMP 3
Buildings A-1, A-2, A-3, and A-10**

IFB 11-15

November 2, 2011

Dayton Metropolitan Housing Authority
400 Wayne Ave.
Dayton, Ohio 45410

This Addendum modifies and shall become a part of the original Contract Documents and is hereby made part of the Bidding Documents for the referenced project.

All bidders shall indicate in their bid/proposal that this Addendum has been received and considered in their bid proposal.

The Addendum items are intended to supplement, clarify or correct parts of the bid proposal package. Items in the addendum shall take precedence over items corrected and shall be of equal value with items supplemented or clarified. Any questions in reference to this addendum must be directed, in writing, to:

Jonathan Schaaf
RDA Group Architects
77 W. Elmwood Drive
Suite 211
Dayton, Ohio 45459
937.610.3440
937.610.3441 Fax
jrs@rda-group.com

Addendum Items:

1. Bathtubs: It is the intent of the project to replace the bathtubs, related bathtub controls, etc. as part of the project. The bathtub shall be American Standard 2391.202 [left or right hand as applicable] or Equal. The drain assembly shall be a lift and turn type stopper 1 ½" NP tubular.
2. Hardwood flooring: It is the intent of the project to sand, stain, and refinish-varnish/polyurethane the floors. The floors will be stained as part of the project.

End of Clarification #1.